

# Is your business safe



## Use the following checklist to make sure

### Address/Suite Numbers

- Address should be posted on or near the front of the business. Numbers should be at least 4" high & with a contrasting background.

### Construction Features

- Ceiling tiles in place
- No holes in walls/fire resistive construction

### Electrical Equipment

- No extension cords being used as permanent wiring
- No multi-plug adapters being used (*power strips are acceptable*)
- No storage blocking electrical panel box (36" clearance)
- over plates in place

### Exits and Fire Escapes

- Emergency lighting is operable
- Exit signs illuminated
- No padlocks/bars on exit doors while occupied
- All exit aisles clear from obstructions

### Fire Alarms

- All pull stations not obstructed from view
- Alarm System has annual test by a permitted company \*

### Fire Extinguishers

- Extinguisher mounted on wall
- Extinguisher has annual test by a permitted company\*
- Extinguisher not obstructed from view
- Maximum travel distance to a fire extinguisher is 75 feet.

### Housekeeping

- Combustibles not stored next to heating source (*i.e. water heater*)
- Housekeeping inside and outside of building is orderly
- No storage in front of exits or exit paths
- No storage within 18" of sprinkler heads
- No storage within 24" of ceiling in unsprinklered areas

### Restaurants/Assembly

- Occupancy load sign posted in the building near front of entrance

### Commercial Kitchens

- Have required K extinguisher for deep fryers
- Hood system is free of grease and cleaned as required by use
- Hood system has current 6 month inspection by permitted company \*

### Sprinkler and Standpipe Systems

- Sprinkler heads are not painted
- System has annual test by a permitted company \*
- Extra sprinkler head's and wrench in sprinkler cabinet

### Storage and Handling of Flammable Liquids Gas

- Compressed gas cylinders must be secured

\* For a list of permitted companies in the City of Pocatello visit <https://www.pocatello.gov/189/Fire>